



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2022-07-11T16:57:14
Measurement time: 2022-07-11 16:57:14
Report time: 2022-07-11 16:57:39

Client name: Azzardo Ligthing
Model name: Bamboo 3
Item No: AZ1901
Serial No.:
Made by: John Smith

Flicker	2069,93 Hz
Flicker index	0,005925
Flicker percent	5,58 %
SVM	0,0034
SAM	2,50
Mp	0,052
VESA flicker	-65,74
JEITA flicker	-68,75
PstLM	0,142


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,253
Flicker percent 400 Hz	0,779
Flicker percent 200 Hz	0,503
Flicker percent 90 Hz	0,312
Flicker percent 40 Hz	0,184

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

