



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-06-11T15:37:08
Measurement time: 2024-06-11 15:37:08
Report time: 2024-06-11 15:37:49

Client name: Azzardo Ligthing
Model name: Dali 30 3000K
Item No: AZ2788
Serial No.:
Made by: John Smith

Flicker	99,80 Hz
Flicker index	0,006861
Flicker percent	6,59 %
SVM	0,02
SAM	-18,98
Mp	0,081
VESA flicker	-61,57
JEITA flicker	-64,58
PstLM	0,139


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,637
Flicker percent 400 Hz	1,315
Flicker percent 200 Hz	1,051
Flicker percent 90 Hz	0,333
Flicker percent 40 Hz	0,167

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

