



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-06-11T13:17:16
Measurement time: 2024-06-11 13:17:16
Report time: 2024-06-11 13:18:59

Client name: Azzardo Ligthing
Model name: Dali 60 3000K
Item No: AZ2792
Serial No.:
Made by: John Smith

Flicker	199,48 Hz
Flicker index	0,007649
Flicker percent	7,11 %
SVM	0,02
SAM	6,04
Mp	0,13
VESA flicker	-57,83
JEITA flicker	-60,84
PstLM	0,141


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	2,042
Flicker percent 400 Hz	1,471
Flicker percent 200 Hz	1,546
Flicker percent 90 Hz	0,283
Flicker percent 40 Hz	0,178

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

