



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2022-08-11T14:25:15
Measurement time: 2022-08-11 14:25:15
Report time: 2022-08-11 14:29:02

Client name: Azzardo Ligthing
Model name: Dali 30 3000K
Item No: AZ2883
Serial No.:
Made by: John Smith

Flicker	99,85 Hz
Flicker index	0,006929
Flicker percent	7,98 %
SVM	0,024
SAM	-33,45
Mp	0,086
VESA flicker	-62,61
JEITA flicker	-65,62
PstLM	0,139


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,822
Flicker percent 400 Hz	1,360
Flicker percent 200 Hz	1,058
Flicker percent 90 Hz	0,290
Flicker percent 40 Hz	0,162

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

