



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2022-07-04T10:39:12
Measurement time: 2022-07-04 10:39:12
Report time: 2022-07-04 10:43:37

Client name: Azzardo Ligthing
Model name: Casper Round 3000K
Item No: AZ4490
Serial No.:
Made by: John Smith

Flicker	99,77 Hz
Flicker index	0,006212
Flicker percent	6,09 %
SVM	0,033
SAM	73,89
Mp	0,11
VESA flicker	-61,11
JEITA flicker	-64,12
PstLM	0,143


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,854
Flicker percent 400 Hz	1,375
Flicker percent 200 Hz	1,222
Flicker percent 90 Hz	0,611
Flicker percent 40 Hz	0,216

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

