



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-06-18T14:20:02
Measurement time: 2024-06-18 14:20:02
Report time: 2024-06-18 14:21:05

Client name: Azzardo Ligthing
Model name: Linnea 112 Pendant Switch CCT
Item No: AZ4569
Serial No.:
Made by: John Smith

Flicker	99,86 Hz
Flicker index	0,005203
Flicker percent	5,38 %
SVM	0,013
SAM	-10,24
Mp	0,063
VESA flicker	-62,04
JEITA flicker	-65,05
PstLM	0,135


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,313
Flicker percent 400 Hz	0,861
Flicker percent 200 Hz	0,631
Flicker percent 90 Hz	0,357
Flicker percent 40 Hz	0,182

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

