



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-08-12T16:52:27
Measurement time: 2024-08-12 16:52:27
Report time: 2024-08-12 16:56:54

Client name: Azzardo Ligthing
Model name: Dali 120 4000K
Item No: AZ5250
Serial No.:
Made by: John Smith

Flicker	99,86 Hz
Flicker index	0,005015
Flicker percent	5,07 %
SVM	0,021
SAM	-22,88
Mp	0,051
VESA flicker	-65,50
JEITA flicker	-68,51
PstLM	0,144


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,638
Flicker percent 400 Hz	1,242
Flicker percent 200 Hz	1,018
Flicker percent 90 Hz	0,408
Flicker percent 40 Hz	0,204

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

