



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-15T16:15:46
Measurement time: 2023-02-15 16:15:46
Report time: 2023-02-15 16:16:13

Client name: Azzardo Ligthing
Model name: AZ5372
Item No: AZ5372
Serial No.:
Made by: John Smith

Flicker	99,78 Hz
Flicker index	0,005813
Flicker percent	5,30 %
SVM	0,016
SAM	-13,41
Mp	0,20
VESA flicker	-49,43
JEITA flicker	-52,44
PstLM	0,366


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,628
Flicker percent 400 Hz	1,353
Flicker percent 200 Hz	1,049
Flicker percent 90 Hz	0,671
Flicker percent 40 Hz	0,460

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

