



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-06T14:32:33
Measurement time: 2023-02-06 14:32:33
Report time: 2023-02-06 14:32:58

Client name: Azzardo Ligthing
Model name: AZ5470
Item No: AZ5470
Serial No.:
Made by: John Smith

Flicker	2343,98 Hz
Flicker index	0,003697
Flicker percent	3,61 %
SVM	0,0022
SAM	2,46
Mp	0,052
VESA flicker	-65,67
JEITA flicker	-68,68
PstLM	0,105


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	0,958
Flicker percent 400 Hz	0,553
Flicker percent 200 Hz	0,370
Flicker percent 90 Hz	0,212
Flicker percent 40 Hz	0,136

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

