



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-08T12:52:49
Measurement time: 2023-02-08 12:52:49
Report time: 2023-02-08 13:11:11

Client name: Azzardo Ligthing
Model name: AZ5475
Item No: AZ5475
Serial No.:
Made by: John Smith

Flicker	50,08 Hz
Flicker index	0,007072
Flicker percent	6,97 %
SVM	0,0069
SAM	-3,70
Mp	0,066
VESA flicker	-58,69
JEITA flicker	-61,71
PstLM	0,141


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,159
Flicker percent 400 Hz	0,769
Flicker percent 200 Hz	0,596
Flicker percent 90 Hz	0,416
Flicker percent 40 Hz	0,151

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

