



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-06T11:24:17
Measurement time: 2023-02-06 11:24:17
Report time: 2023-02-06 11:25:12

Client name: Azzardo Ligthing
Model name: AZ5486
Item No: AZ5486
Serial No.:
Made by: John Smith

Flicker	3100,13 Hz
Flicker index	0,002149
Flicker percent	2,07 %
SVM	0,0011
SAM	2,40
Mp	0,037
VESA flicker	-68,05
JEITA flicker	-71,06
PstLM	0,0619


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	0,493
Flicker percent 400 Hz	0,315
Flicker percent 200 Hz	0,223
Flicker percent 90 Hz	0,173
Flicker percent 40 Hz	0,112

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

