



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-07T14:38:10
Measurement time: 2023-02-07 14:38:10
Report time: 2023-02-07 14:39:58

Client name: Azzardo Ligthing
Model name: AZ5487
Item No: AZ5487
Serial No.:
Made by: John Smith

Flicker	49,88 Hz
Flicker index	0,007244
Flicker percent	6,94 %
SVM	0,01
SAM	-4,06
Mp	0,073
VESA flicker	-55,17
JEITA flicker	-58,18
PstLM	0,146


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,396
Flicker percent 400 Hz	0,909
Flicker percent 200 Hz	0,760
Flicker percent 90 Hz	0,717
Flicker percent 40 Hz	0,339

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

