



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-27T14:15:37
Measurement time: 2023-02-27 14:15:37
Report time: 2023-02-27 14:23:31

Client name: Azzardo Ligthing
Model name: AZ5502
Item No: AZ5502
Serial No.:
Made by: John Smith

Flicker	128,58 Hz
Flicker index	0,00574
Flicker percent	5,90 %
SVM	0,0034
SAM	-6,48
Mp	0,078
VESA flicker	-59,32
JEITA flicker	-62,33
PstLM	0,138


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,071
Flicker percent 400 Hz	0,658
Flicker percent 200 Hz	0,475
Flicker percent 90 Hz	0,299
Flicker percent 40 Hz	0,162

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

