



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2023-02-21T13:50:04
Measurement time: 2023-02-21 13:50:04
Report time: 2023-02-21 13:51:06

Client name: Azzardo Ligthing
Model name: AZ5513
Item No: AZ5513
Serial No.:
Made by: John Smith

Flicker	2997,53 Hz
Flicker index	0,002652
Flicker percent	2,76 %
SVM	0,0016
SAM	2,41
Mp	0,036
VESA flicker	-68,98
JEITA flicker	-71,99
PstLM	0,0765


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	0,605
Flicker percent 400 Hz	0,351
Flicker percent 200 Hz	0,233
Flicker percent 90 Hz	0,155
Flicker percent 40 Hz	0,0883

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

