



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-09-30T15:40:48
Measurement time: 2024-09-30 15:40:48
Report time: 2024-09-30 15:49:44

Client name: Azzardo Ligthing
Model name: Linnelio OPAL 120 CCT DIMM
Item No: AZ5657
Serial No.:
Made by: John Smith

Flicker	98,48 Hz
Flicker index	0,00491
Flicker percent	4,39 %
SVM	0,0029
SAM	-4,70
Mp	0,10
VESA flicker	-61,35
JEITA flicker	-64,36
PstLM	0,133


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,336
Flicker percent 400 Hz	0,685
Flicker percent 200 Hz	0,456
Flicker percent 90 Hz	0,299
Flicker percent 40 Hz	0,193

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

