



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-09-19T17:12:57
Measurement time: 2024-09-19 17:12:57
Report time: 2024-09-19 17:14:47

Client name: Azzardo Ligthing
Model name: Alamo Pendant 120 3-Step Dimm
Item No: AZ5766
Serial No.:
Made by: John Smith

Flicker	99,78 Hz
Flicker index	0,01625
Flicker percent	9,56 %
SVM	0,18
SAM	1,99
Mp	0,08
VESA flicker	-63,31
JEITA flicker	-66,32
PstLM	0,141


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	5,986
Flicker percent 400 Hz	5,783
Flicker percent 200 Hz	5,692
Flicker percent 90 Hz	2,605
Flicker percent 40 Hz	0,556

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

