



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-10-02T17:13:00
Measurement time: 2024-10-02 17:13:00
Report time: 2024-10-02 17:20:55

Client name: Azzardo Ligthing
Model name: Alfa 2Line Optica 12W CCT Switch
DIMM
Item No: AZ6256
Serial No.:
Made by: John Smith

Flicker	75,01 Hz
Flicker index	0,005323
Flicker percent	5,28 %
SVM	0,0035
SAM	-3,89
Mp	0,098
VESA flicker	-61,52
JEITA flicker	-64,53
PstLM	0,138


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,103
Flicker percent 400 Hz	0,666
Flicker percent 200 Hz	0,469
Flicker percent 90 Hz	0,283
Flicker percent 40 Hz	0,170

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

