



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-04-22T12:32:42
Measurement time: 2024-04-22 12:32:42
Report time: 2024-04-22 12:33:04

Client name: Azzardo Ligthing
Model name: Tetris 5 CCT GIPS WH
Item No: AZ6275
Serial No.:
Made by: John Smith

Flicker	100,00 Hz
Flicker index	0,005683
Flicker percent	5,62 %
SVM	0,011
SAM	-9,36
Mp	0,089
VESA flicker	-59,84
JEITA flicker	-62,85
PstLM	0,141


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,336
Flicker percent 400 Hz	1,001
Flicker percent 200 Hz	0,796
Flicker percent 90 Hz	0,365
Flicker percent 40 Hz	0,220

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

